

DISTRICT WATER TESTING LABORATORY, ROOPNAGAR

Department of Water Supply and Sanitation, Division -2, Roopnagar
dwtlpr@gmail.com

To,

Navpreet Kaur
dreamland Public School Bassi Gujran Near Chamkaur Sahib


No.: DWTLRPR/2324/00100 Dated : 09/10/2023

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. letter no. Adm104/09/2023 Dated: 28/09/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 28/09/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Roopnagar

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Roopnagar**


Principal
Dreamland Public School
Bassi Gujran (Ropar)

DISTRICT WATER TESTING LABORATORY, ROOPNAGAR


Department of Water Supply and Sanitation, Division -2, Roopnagar
dwtlrpr@gmail.com

TEST REPORT

Name & Address of Customer : Navpreet Kaur dreamland Public School Bassi Gujran Near Chamkaur Sahib	Customer Reference No.	No : letter no. Adm104/09/2023 Dated : 28/09/2023
	Sample Submitted by	Navpreet kaur
	Date of Sample Receipt	28/09/2023
	Analysis Starting Date	04/10/2023
	Analysis completion Date	06/10/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC988223000000133F	Sample Type :	Water
Test Report No.:	DWTLRPR/2324/00100	Date of Issue :	09/10/2023
Registration no.:	DWTLRPR/REG2324/00442	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Dreamland Public School Bassi Gujran, Near Chamkaur Sahib / NA
Village :	Basi Gujran	Habitation :	Basi Gujran
Block:	Chamkaur Sahib	District :	Roopnagar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.52	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	250	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.46	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	192	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	160	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	36.87	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	16.52	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method


 Principal
 Dreamland Public School
 Bassi Gujran (Ropar)

DISTRICT WATER TESTING LABORATORY, ROOPNAGAR

Department of Water Supply and Sanitation, Division -2 , Roopnagar
dwtlrpr@gmail.com

11	Chloride	31	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---


This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$



Mr. Manik Kataria
Sr. Chemist
Authorized Signatory
For, District Water Testing Laboratory
Roopnagar

----- End of the Test Report -----


Principal
Dreamland Public School
Bassi Gujran (Ropar)